

# Preliminary Assessment Report

## Project 3022258, 4025 13TH AVE W

---

**Assessment Completed:** 12/7/2015

**Project Description:** Floating Boat Shed (case #1034287)

**Primary Applicant:** [Joseph Brogan](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

### Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

### Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

#### DPD Drainage Requirements

Eric Dripps, (206) 727-3676, [Eric.Dripps@seattle.gov](mailto:Eric.Dripps@seattle.gov)

#### DPD Land Use Requirements

Christina B Capestany, (206) 233-2170, [tina.capestany@seattle.gov](mailto:tina.capestany@seattle.gov)

#### DPD Preapplication Site Visit Requirements

Douglas Thresher, (206) 233-3875, [Douglas.Thresher@seattle.gov](mailto:Douglas.Thresher@seattle.gov)

#### Seattle City Light Requirements

Ray Ramos, (206) 615-1193, [ray.ramos@seattle.gov](mailto:ray.ramos@seattle.gov)

#### Seattle Department of Transportation Requirements

Leo Kaarrekoski, [leo.kaarrekoski@seattle.gov](mailto:leo.kaarrekoski@seattle.gov)

#### Seattle Public Utilities Requirements

Lan Chau, (206) 727-3584

#### Water Availability

SPU Staff, (206) 684-3333, [SPUWaterAvailability@Seattle.Gov](mailto:SPUWaterAvailability@Seattle.Gov)

## Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

## Requirements

### **DPD Drainage Requirements**

The following requirements are based on the current stormwater and side sewer codes.

#### **Drainage**

The drainage point of discharge (SMC 22.805.020) is located at: Direct to receiving water.

**\*\*Alert\*\* Drainage requirements indicated in this Preliminary Assessment Report are per the 2009 Stormwater Code and Manual. The new 2016 Stormwater Code and Manual will become effective on January 1, 2016. The new rules will replace the current Stormwater Code and Directors' Rules. Projects with accepted applications on or after January 1, 2016 will be subject to the new 2016 Stormwater Code and Directors' Rules.**

#### **Flow Control Compliance**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. A completed [Construction Stormwater Control and Soil Amendment Standard Plan](#) is required.

#### **Water Quality**

No requirements

#### **Wastewater**

The wastewater point of discharge (SMC 21.16.070.B) is located at Private Sewer Main.

#### **Permanent and Temporary Dewatering**

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following:  
Direct to receiving water.

### **DPD Land Use Code Requirements**

#### **Street Requirements**

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

##### **13TH AVE W**

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

Other requirements: Site does not appear to abut 13th Avenue W.

#### **Land Use**

Based on the project scope and/or location of environmentally critical areas on the development site, SEPA may be required. See CAM 208 for more details.

A shoreline substantial development permit is required, unless the project qualifies for a specific exemption from the Shoreline Master Program. See CAM 209 and 209A for more details. Application and decision on the exemption must be made before submission of an application.

Based on the preliminary scope, the project may qualify for a specific exemption under the City's Shoreline Master Program. Application and decision on the exemption must be made before submission of an application.

## **Pre-Application Site Visit (PASV) Requirements**

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

**Note:** Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

The site plan did not include the following existing or proposed elements:

Site is on the end of a pier so no street report is included.

### **ECA Mapping Unit and Type**

This project site appears to include the following ECAs and/or buffers:

Liquefaction

### **Potential Impacts to Seattle Parks Property**

No parks property in vicinity

### **Tree Protection**

Existing trees appear to be shown accurately on the site plan

### **Possible Exemptions from ECA Submittal Requirements**

Applicability of exemption from submittal requirements **must** be confirmed at permit application intake; the standards of the ECA Ordinance still apply.

Maintenance, repair, renovation, or structural alteration of structure existing on October 31, 1992 (see [25.09.045 F](#))

### **Standard Submittal Requirements for Projects in an ECA**

The site is mapped as liquefaction prone. A geotechnical report is required to address liquefaction potential and, if needed, mitigation (see [SMC 25.09.100](#)).

## **Seattle City Light Requirements**

### **Notes to Applicant**

For SCL-related electrical advice or consultation, please contact your Electrical Service Representative well in advance. Your Electrical Service Representative is: Dennis Dolezal, 206-684-4977, [dennis.dolezal@seattle.gov](mailto:dennis.dolezal@seattle.gov). Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

## **SDOT Requirements**

Based on the information provided at this time, it appears that no street improvements are **required**. All work in the right-of-way requires a permit. Therefore, if you are planning discretionary improvements you should contact SDOT as soon as possible. Be advised that it is the applicant's responsibility to seek guidance from SDOT Street Use should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SDOT at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

## **SPU Requirements**

### **Water Availability**

Your water availability assessment has been approved.

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

[http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos\\_004542.pdf](http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf). For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, [Liz.Kain@seattle.gov](mailto:Liz.Kain@seattle.gov).

### **Other Requirements**

## **Other Requirements**

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or [www.seattle.gov/neighborhoods/preservation](http://www.seattle.gov/neighborhoods/preservation) to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, [Michale.Crooks@seattle.gov](mailto:Michale.Crooks@seattle.gov), or visit the [Licensing and Tax Administration Division website](#).